





Second Floor Office Plan 3/16" = 1'-0"

REVISIONS	BY
2-18-94	

Architect
Rodríguez
Perera
Architects, Inc.
10540 N.W. 20th St., Suite 101, Miami, FL 33172
(305) 582-8045




Signature
Date: 2-18-94

15

Corporate Headquarters for:
Pharmed Group Corp.
Dade County, Florida

Date	2-18-94
Scale	
Drawn	
Job	9301
Sheet	A-7
Of	8 Sheets

THROUGH-PENETRATION FIRESTOP SYSTEM for PIPE/CONDUIT THROUGH CONCRETE FLOOR/WALL



- COMMENTS:**
- Clean and dry substrate surfaces.
 - Install damming material to proper depth.
 - Install FYRE-SHIELD and tool to insure intimate contact to all surfaces.
 - IMMEDIATE FIRE RATING ACHIEVED!
- These comments are based on FYRE-SHIELD's performance per ASTM-E814 (UL 1479) Fire Test and UL Through Penetration Firestop System No. 208.

SYSTEM CHARACTERISTICS

1. PENETRATION TYPE	2. PENETRATION SIZE	3. PENETRATION MATERIAL	4. PENETRATION METHOD	5. PENETRATION RATING	6. PENETRATION COMMENTS
CONCRETE FLOOR/WALL	4" - 12"	Steel Pipe, Conduit, or Duct	Drill and Install	1, 2, 3	See Notes
CONCRETE WALL	4" - 12"	Steel Pipe, Conduit, or Duct	Drill and Install	1, 2, 3	See Notes
CEILING	4" - 12"	Steel Pipe, Conduit, or Duct	Drill and Install	1, 2, 3	See Notes
FLOOR	4" - 12"	Steel Pipe, Conduit, or Duct	Drill and Install	1, 2, 3	See Notes

