



Space Profile for

Unit: #0047

Area: 984 sq ft

Address

*4200 S. East Street, Ste. 47*


*Indianapolis, IN 46227*



*400 N. Tampa St., Suite 2210*

*Tampa, FL, 33602*





# Legend

	Breaker Panel		Fire Extinguisher		Ceiling Fan w/ Light		Fire Sprinkler
	Circular Column		Fire Alarm Pulldown		Rectangular Column		Pocket Door
	Appliance Outlet		Glass Door		Refrigerator		Track Lighting
	Fire Alarm		Handicap Handrail		Roll-Up Door		2-Bulb Fluorescent Lighting
	Drinking Fountain		Roof Hatch		Sink		3-Bulb Fluorescent Lighting
	Door		HVAC Unit		Swing Door		4-Bulb Fluorescent Lighting
	Double Hung Door		Recessed Light		Toilet		Ceiling Air Vent
	Electrical Outlet		Staircase		Can Light		Air Diffuser
	Emergency Light		Water Heater		Urinal		Ceiling Fan w/o Light
	EXIT Light		Telephone Panel		Thermostat		Air Handler
	Tankless Water Heater		Window Wall Opening		RJ 45		Fire Alarm Control Panel
	Step Down Transformer		Maintenance Sink		Window		Tenant Water Meter
	Disconnect		Sub Water Meter		House Gas Meter		Sub Gas Meter
	House Water Meter		Air Handler		House Electric Meter		Tenant Electric Meter
	Tenant Gas Meter						
	Sub Electric Meter						



## Space Overview

Overview	Actual Square Footage	Measured Depth of Space	Total Depth of Space	Has Stepdown Transformer
	984 SQFT	46' 0"	46' 0"	No

Thickness	Front Wall	Rear Wall	Left Wall	Right Wall
	0' 5"	0' 9"	1' 0"	0' 10"

Flooring	Concrete	Carpet	Tile	Other	Unit	Total
	925.26 SQFT					984 SQFT

Ceiling Information	Height From Floor To Ceiling	Height From Floor To Bottom Of Deck	Height From Floor To Bottom Of Joist
	Front: 20' 4" Back: 14' 3"	Front: 20' 4" Back: 14' 3"	Front: 12' 1" Back: 12' 1"

Ceiling Information Cont.	Clear Ceiling Height	Height From Floor To Bottom Of Girder	Number Of Acoustical Tiles
	6' 10"		

Other Cont.	Phone Board Location	Mop Sink Location	Thermostat Location	Dmarc Distance	Are Interior Walls Full Height
					No

Other Cont.	Hazardous Materials	Loading Dock	Are Demising Walls Full Height	Changes In Demising Wall Thickness
	No	No	No	No

Mechanical

HVAC	Reference	Manufacturer	Model	Serial	Tonnage	Year	Notes
	2	TRANE	YCH090A3H0AC	F871433930	7.5	1991	

Electric

Service Panel	Reference	Amps	Service Type	Panel Type	Panel UL Number	Manufacturer	Location	Notes
	1	0	Not Listed	QO Load Center	Not Listed	Square D	Open Space; Rear Wall	Label Faded, Amps Not Listed

Disconnect	Reference	Amps	Location	Panel Number	Manufacturer	Notes	Handle or Breaker
	4	200	Open Space; Rear Wall	Not Listed	Square D		Breaker

Electric Meter	Reference	Meter #	Location	Meter Reading	Read On	Voltage	Notes
	4	1074497	Rear Exterior Wall Mounted				120-277V

\*IDPlans does not provide an Ampacity Report\*

## Plumbing

Water Meter	Reference	Meter #	Location	Size	Notes
	8	NO METER	Right Exterior Ground Meter Box	N/A	Removed Per Water Company

## Waste

No assets available for this section.

## Fire

No assets available for this section.

Gas

Gas Meter	Reference	Meter #	Location	Size	Notes
	3	542419	Right Side Exterior Wall Mounted	1/2 inch	

## Room

No assets available for this section.

# Storefront 1

