

EXISTING/NEW DOOR SCHEDULE				
DOOR NO	QAN	SIZE	MATERIAL	HARDWARE
D01	EXIST	2 3'X7'	HOLLOW METAL	METAL HANDLE - 603 (F&E) CLOSED POSITION - 602 (F&E) - AUTO CLOSER
D02	EXIST	4 3'X6'-8"	HOLLOW METAL	COMMERCIAL LEVER
D03	EXIST	1 2'-0"X6'-8"	HOLLOW WOOD	COMMERCIAL LEVER
D04	EXIST	1 2'-0"X6'-0"	HOLLOW WOOD	COMMERCIAL LEVER
D05	EXIST	3 3'X6'-8"	HOLLOW WOOD	COMMERCIAL LEVER, AUTO LOCK SYSTEM AUTO CLOSER OR SELF CLOSER HINGES
D06	EXIST	2 3'X6'-8"	HOLLOW WOOD	COMMERCIAL LEVER
D07	EXIST	30 10'X10'	METAL ROLL UP	ROLLING UP DOOR LOCK SYSTEM
ND01	NEW	1 3'X6'-8"	HOLLOW METAL	PANIC PUSH BAR HARDWARE - AUTO CLOSER

EXISTING/NEW WALL LEGEND	
	EXISTING 8" EXTERIOR/INTERIOR CMU WALL
	EXISTING 10" EXTERIOR PRE-CAST CONCRETE WALL
	EXISTING 4" EXTERIOR PRE-FAB METAL WALL
	NEW 8" EXTERIOR (FILLER) CMU WALL 10'-0" HIGH (SEE WALL SECTION A-A)
	NEW 6" 2-HR DMISSING WALL 16'-0"X16'-4" HIGH (SEE 2-HR WALL SECTION ACCORDING TO UL LISTED A19)
	NEW 6" 2-HR FILLER WALL 10'-0" HIGH (SEE 2-HR WALL SECTION ACCORDING TO UL LISTED A19)

- FIRE PROTECTION NOTES:**
- FLORIDA FIRE PREVENTION CODE 2017, 6TH EDITION BASED ON NFPA 1 FIRE CODE 2015 EDITION & NFPA 10 LIFE SAFETY CODE 2015 EDITION
 - THE SPACE HAVE NO FIRE SPRINKLER SYSTEM
 - INSTALL TECTILE SIGN FOR EXIT DOORS PER NFPA 101-7.10.1.3
 - ROOF STRUCTURAL SYSTEM IS HEAVY STRUCTURAL, SHOULD NOT COMPLY WITH THE REQUIREMENT OF FAC 69A-60.0081.
 - THE MAIN ELECTRICAL DISCONNECT ON THE INSIDE OF THE EXTERIOR NORTHWESTERN WALL
 - ELECTRICIAN SHOULD INSTALL THE ELECTRICAL SIGNAGE PER NFPA

LEGEND	
	EXISTING EXIT SIGN / EMERGENCY LIGHT
	EXIT SIGN
	EMERGENCY LIGHT
	FIRE EXTINGUISHER

